

**WOOD/COAL BURNING  
STOVE  
SUPPLEMENTAL INSPECTION FORM**

Applicant's Name \_\_\_\_\_

<b>Stove/Furnace Unit</b>	Type	<input type="checkbox"/> Open Hearth (No doors)	<input type="checkbox"/> Pot Belly, Box or Franklin (Loose fitting doors)	<input type="checkbox"/> Airtight (Tight-fitting, draft-limiting doors and seams)	
	Construction	<input type="checkbox"/> Sheet Metal	<input type="checkbox"/> Cast Iron	<input type="checkbox"/> Brick Lined	Any Cracks or Broken Parts? <input type="checkbox"/> Yes <input type="checkbox"/> No
	Fuel	<input type="checkbox"/> Wood	<input type="checkbox"/> Coal	<input type="checkbox"/> Other (specify): _____	
	Principal Use	<input type="checkbox"/> Primary Heat Source (More than 50 days/yr.)		<input type="checkbox"/> Supplemental Heating (Less than 50 days/yr.)	<input type="checkbox"/> Cooking
	Installed By	<input type="checkbox"/> Owner	<input type="checkbox"/> Contractor	Month/Year of Installation _____/_____	
	Inspected By	<input type="checkbox"/> Building Inspector	<input type="checkbox"/> Fire Department	<input type="checkbox"/> Other (specify): _____	

<b>Chimney/Chimney Connector (Stove Pipe)</b>	Installation	Stove placed at least 36" from combustible well or furnishings, or 18" from non-combustible shield with 1" air space to combustible wall. <input type="checkbox"/> Yes <input type="checkbox"/> No	Non-combustible pad or surface below stove, extends at least 18" beyond loading door and 12" beyond side and rear. <input type="checkbox"/> Yes <input type="checkbox"/> No	Stove legs allow at least 4" air space below stove. <input type="checkbox"/> Yes <input type="checkbox"/> No
	Type	<input type="checkbox"/> Masonry <input type="checkbox"/> U.L. Listed Metal Chimney		
	Cleaned/ Inspected	When last cleaned _____/_____/____ (Mo. Yr.)	Last inspected _____/_____/____ (Mo. Yr.)	Are ashes disposed of in a fireproof container? <input type="checkbox"/> Yes <input type="checkbox"/> No
	Installation	Passes through non-combustible thimble collar or opening which is at least 12" larger in diameter than stove pipe: <input type="checkbox"/> Yes <input type="checkbox"/> No  More than two bonds: <input type="checkbox"/> Yes <input type="checkbox"/> No	Connector to chimney under 10' in length: <input type="checkbox"/> Yes <input type="checkbox"/> No  Horizontal portion rises at least 1/4" per linear ft. of pipe length so chimney connection point is higher than stove end: <input type="checkbox"/> Yes <input type="checkbox"/> No	Galvanized steel pipe: <input type="checkbox"/> Yes <input type="checkbox"/> No  Pipe sections overlap to contain creosote flow back: <input type="checkbox"/> Yes <input type="checkbox"/> No

